

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-039189



DISTRICT OFFICE

Property Maintenance Unit
9359 Krewstown Rd
Philadelphia, PA 19115
215-685-0535
PropertyMaintenanceUnit@phila.gov

PROPERTY IN VIOLATION

8216-28 FRANKFORD AVE, Philadelphia, PA 19136-2342

DATE OF NOTICE

07/01/2026

On 06/30/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 08/04/2026

VIOLATIONS

PHILA. CODE § PM15-603.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All mechanical appliances, fireplaces, solid fuel-burning appliances, cooking appliances and water heating appliances shall be properly installed and maintained in a safe working condition, and shall be capable of performing the intended function.		
CONDITION IN VIOLATION Have a licensed contractor repair/ replace broken HVAC system.		
LOCATION Building A Apartment A3		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-039189

VIOLATIONS

PHILA. CODE § F-604.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible code official. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.		
CONDITION IN VIOLATION Have a licensed contractor repair/ replace broken HVAC system. Remove exposed wires in closet.		
LOCATION Building A Apt A3		
PHILA. CODE § F-1103.9.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Carbon monoxide alarms shall be installed in accordance with Section 915.2. Where the alarm is a combination smoke and carbon monoxide alarm, it shall be located in accordance with the installation instructions for the smoke alarm.		
CONDITION IN VIOLATION Install CO2 detector in unit.		
LOCATION Building A Apartment A3		
PHILA. CODE § F-1103.8.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Existing Group R occupancies and dwellings shall be provided with single-station smoke alarms. Where installation is required to meet the requirements of this section, the smoke alarms shall be installed in accordance with Section 907.2.10, except as permitted in this section.		
CONDITION IN VIOLATION Install working smoke detectors in unit.		
LOCATION Building A Apartment A3		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-039189

VIOLATIONS

PHILA. CODE § PM15-305.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Every interior door shall fit reasonably well within its frame and shall be capable of being opened and closed by being properly and securely attached to jambs, headers, or tracks.		
CONDITION IN VIOLATION Repair/ replace closet door knob.		
LOCATION Building A Apartment A3		

PHILA. CODE § PM15-403.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every bathroom and toilet room shall be equipped with mechanical or natural ventilation. A window shall not be required in such spaces equipped with a mechanical ventilation system. Air exhausted by a mechanical ventilation system from a bathroom or toilet room shall discharge to the outdoors and shall not be recirculated.		
CONDITION IN VIOLATION Repair/replace damaged bathroom exhaust fan.		
LOCATION Building A Apartment A3 Bathroom		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-039189

VIOLATIONS

PHILA. CODE § PM15-504.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Plumbing fixtures shall have adequate clearances for usage and cleaning.		
CONDITION IN VIOLATION Reinstall toilet so that it has better clearance un use and clearance. It is currently partially in the wall.		
LOCATION Building A Apartment A3 Bathroom		

PHILA. CODE § PM15-504.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks and defects and be capable of performing the function for which such plumbing fixtures are designed. All plumbing fixtures shall be maintained in a safe, sanitary and functional condition.		
CONDITION IN VIOLATION Recalk tub and reattach the shower wall to prevent leaks and water damage.		
LOCATION Building A Apartment A3 Bathroom		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-039189



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 07/31/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: Kadeem Jackson Kadeem.Jackson@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

پر کال کریں 215-686-8686 **ترجمے کی خدمات کے لیے!** یہ ایک ضروری اطلاع نامہ ہے: **توجہ فرمائیے**

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686