

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080035



DISTRICT OFFICE

Fire Safety Unit
5th Fl
2401 Walnut St
Philadelphia, PA 19103
215-685-3917
FireSafetyUnit@phila.gov

PROPERTY IN VIOLATION

4035 CHESTNUT ST, Philadelphia, PA 19104-3055

DATE OF NOTICE

07/03/2026

On 07/02/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 08/06/2026

VIOLATIONS

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080035

VIOLATIONS

PHILA. CODE § F-901.7	FINE AMOUNT \$1,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE "Where a required fire protection system is out of service, the fire department shall be notified immediately in accordance with, and under the conditions specified in Section F-106.5.1. Out of service fire protection systems in vacant buildings shall be subject to the requirements of Section 311. Where required by the fire code official, the building shall either be evacuated, or an approved fire watch shall be provided for all occupants left unprotected by the shutdown until the fire protection system has been returned to service. Where utilized, fire watches shall be provided with at least one approved means for notification of the fire department and their only duty shall be to perform constant patrols of the protected premises and keep watch for fires. In the event that the fire watch observes smoke or fire, the fire department shall be notified immediately. The fire department shall be notified upon the return of the system to service. The duties of the fire watch are as follows: 1. An adequate number of fire watch personnel shall be on duty to ensure that all areas of a property are inspected every 30 minutes. In multi-story buildings there shall be at least one fire watch for every five floors. 2. At the beginning of the fire watch, fire watch personnel shall notify occupants of the temporary means by which they will be notified of the need to evacuate. A compressed air horn or other loud sounding device shall be used to alert occupants to evacuate the building in the event of smoke or fire. 3. Fire watch personnel shall be trained in their duties in accordance with Section 406. 4. A log shall be maintained of all fire watch activities."		
CONDITION IN VIOLATION FIRE ALARM SYSTEM OUT OF SERVICE		
LOCATION 4035 CHESTNUT ST		

PHILA. CODE § F-903.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Sprinkler systems shall be tested and maintained in accordance with Section 901.		
CONDITION IN VIOLATION HAVE A LICENSED CONTRACTOR INSPECT AND CERTIFY THE FIRE SUPPRESSION SYSTEM AND UPLOAD THE CERTIFICATION TO ECLIPSE.PHILA.GOV		
LOCATION 4035 CHESTNUT ST		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080035

VIOLATIONS

PHILA. CODE § F-901.6.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The testing of fire protection systems shall be in accordance with Sections 901.6 and F-901.6.4 through F-901.6.4.8.1. Annually the owner of each building that contains fire protection systems shall have such systems certified as operating properly by a person certified or licensed by the Department of Licenses and Inspections to provide such certifications in accordance with this Section. Certification forms shall be maintained on the property and made available for inspection upon the request of a fire code official. The certification form shall be submitted to the Department of Licenses and Inspections which may, by regulation, establish a fee to be paid upon submission of the form.		
CONDITION IN VIOLATION HAVE A LICENSED CONTRACTOR INSPECT AND CERTIFY THE FIRE ALARM SYSTEM AND UPLOAD THE CERTIFICATION TO ECLIPSE.PHILA.GOV		
LOCATION 4035 CHESTNUT ST		

PHILA. CODE § F-509.1.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Where required by the fire code official, gas shutoff valves, electric meters, service switches and other utility equipment shall be clearly and legibly marked to identify the unit or space that it serves. Identification shall be made in an approved manner, readily visible and shall be maintained.		
CONDITION IN VIOLATION INSTALL SIGNAGE FOR GAS METER ROOM AND ELECTRICAL ROOM		
LOCATION 4035 CHESTNUT ST - THE BRANDEN APARTMENT BUILDING: 1ST FLOOR		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080035

VIOLATIONS

PHILA. CODE § PM15-304.13	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.		
CONDITION IN VIOLATION REPAIR ELECTRICAL ROOM WINDOW		
LOCATION 4035 CHESTNUT ST - THE BRANDEN APARTMENT BUILDING		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 08/02/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080035



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: Elijah Ellis
Elijah.Ellis@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

پر کال کریں 215-686-8686 **ترجمے کی خدمات کے لیے!** یہ ایک ضروری اطلاع نامہ ہے: **توجہ فرمائیں**

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686

