

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080561



DISTRICT OFFICE

Property Maintenance Unit
9359 Krewstown Rd
Philadelphia, PA 19115
215-685-0535
PropertyMaintenanceUnit@phila.gov

PROPERTY IN VIOLATION

7233 DUNGAN RD, Philadelphia, PA 19111-4102

DATE OF NOTICE

07/04/2026

On 07/03/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 08/07/2026

VIOLATIONS

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080561

VIOLATIONS

PHILA. CODE § PM15-704.2	FINE AMOUNT \$1,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Single- or multiple-station smoke alarms shall be installed and maintained in Groups R-2, R-3, R-4 and in dwellings not regulated in Group R occupancies, regardless of occupant load at all of the following locations: 1 On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms. 2 In each room used for sleeping purposes. 3 In each story within a dwelling unit , including basements and cellars but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level. Single- or multiple-station smoke alarms shall be installed in other groups in accordance with the International Fire Code.		
CONDITION IN VIOLATION Replace Smoke detectors located in Livingroom and Bedroom		
LOCATION Apartment Unit 1 (Side Door Entrance)		

PHILA. CODE § F-1103.9	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Carbon monoxide alarms shall be installed in existing dwelling units or sleeping units in accordance with Sections F-1103.9.1 through F-1103.9.3 where any of the conditions in Sections 915.1.2 through 915.1.6 exist. A carbon monoxide detection system installed in accordance with Section 915.5 shall be an acceptable alternative to carbon monoxide alarms.		
CONDITION IN VIOLATION Install Carbone Monoxide alarm		
LOCATION Apartment Unit 1		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080561

VIOLATIONS

PHILA. CODE § PM15-604.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The electrical system at the premises constitutes a hazard to the occupants due to one or more of the following: inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the defects must be corrected to eliminate the hazard.		
CONDITION IN VIOLATION Repair or replace non-working electrical outlets located in living room, kitchen and bedroom. Repair hanging ceiling light in basement.		
LOCATION Apartment Unit 1		

PHILA. CODE § F-604.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.		
CONDITION IN VIOLATION Excessive use of extension cords possesses a fire hazard; remove extension cords		
LOCATION Apartment Unit 1 & Basement		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080561

VIOLATIONS

PHILA. CODE § F-604.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.		
CONDITION IN VIOLATION Repair & cover electrical outlet located above stove top. Repair & cover open ceiling outlet box in basement.		
LOCATION Kitchen & Basement		
PHILA. CODE § PM15-305.1(e)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Stairs, landings, balconies and all similar walking surfaces, including guards and handrails, are not structurally sound, not properly anchored or are anchored with connections not capable of supporting all nominal loads and resisting all load effects.		
CONDITION IN VIOLATION Replace kitchen floor tiles.		
LOCATION Kitchen		
PHILA. CODE § PM15-304.10	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.		
CONDITION IN VIOLATION Repair deteriorated steps		
LOCATION Basement		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-080561



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 08/03/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: DIANA OLIVERAS Diana.Oliveras@Phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

پر کال کریں 215-686-8686 **ترجمے کی خدمات کے لیے!** یہ ایک ضروری اطلاع نامہ ہے: **توجہ فرمائیے**

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686