



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-007006



DISTRICT OFFICE

Property Maintenance Unit
5TH FLR
2401 Walnut St
Philadelphia, PA 19103
215-683-0575

PROPERTY IN VIOLATION

3130-42 N 16TH ST, Philadelphia, PA 19132-2338

DATE OF NOTICE

01/29/2021

On 01/28/2021 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 03/04/2021

VIOLATIONS

PHILA. CODE § PM15-109.1	FINE AMOUNT \$2,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The Department has deemed the structure referenced in this order Unfit. A structure is unfit for human occupancy whenever the code official finds that such structure is unsafe, unlawful or, because of the degree to which the structure is in disrepair or lacks maintenance, is unsanitary, vermin or rat infested, contains filth and contamination, or lacks ventilation, illumination, sanitary or heating facilities or other essential equipment required by this code, or because the location of the structure constitutes a hazard to the occupants of the structure or to the public. The owner shall be prohibited from admitting any new tenants to any tenant space within such dwelling for the duration of such unfit designation.		
CONDITION IN VIOLATION raw sewage in kitchen sink (unit A2)		
LOCATION unit A2		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-007006

VIOLATIONS

PHILA. CODE § PM15-504.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The plumbing system in this structure constitutes a hazard to the occupants due to one or more of the following: inadequate service, inadequate venting, cross connection, back siphonage, improper installation, deterioration or damage or for similar reasons, and must be corrected to eliminate the hazard.		
CONDITION IN VIOLATION raw sewage in kitchen sink (unit A2)		
LOCATION kitchen (unit		

PHILA. CODE § PM15-506.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every plumbing stack, vent, waste and sewer line shall function properly and be kept free from obstructions, leaks and defects.		
CONDITION IN VIOLATION raw sewage in kitchen sink		
LOCATION kitchen (unit A2)		

PHILA. CODE § PM15-504.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks and defects and be capable of performing the function for which such plumbing fixtures are designed. All plumbing fixtures shall be maintained in a safe, sanitary and functional condition.		
CONDITION IN VIOLATION raw sewage in kitchen sink		
LOCATION unit A2		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-007006

VIOLATIONS

PHILA. CODE § PM15-603.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All mechanical appliances, fireplaces, solid fuel-burning appliances, cooking appliances and water heating appliances shall be properly installed and maintained in a safe working condition, and shall be capable of performing the intended function.		
CONDITION IN VIOLATION repair stove that was tagged by Philadelphia Gas Works		
LOCATION unit A2		

PHILA. CODE § PM15-309.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The owner of a structure containing two or more dwelling units, a multiple occupancy , a rooming house or a nonresidential structure shall be responsible for extermination in the public or shared areas of the structure and exterior property. If infestation is caused by failure of an occupant to prevent such infestation in the area occupied, the occupant and owner shall be responsible for extermination.		
CONDITION IN VIOLATION pest control		
LOCATION unit A2		

PHILA. CODE § FC-13-915	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Property owners are required to have fire suppression, alarm, Emergency/Standby Power, and other emergency electrical systems inspected and certified annually by an individual or company licensed by the Department of Licenses and Inspections. The certification(s) must be kept on site for three years and made available for review F-915		
CONDITION IN VIOLATION provide current fire alarm certification		
LOCATION 3130-42 n 16th st		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-007006

VIOLATIONS

PHILA. CODE § FC-13-1008.2.5		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Exit doors must be self closing and latching to prevent smoke intrusion F-1008.2.5			
CONDITION IN VIOLATION fire exit on 1st floor not latching			
LOCATION 1st floor fire exit			

PHILA. CODE § PM15-302.1		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All exterior property and premises must be maintained in a clean, safe and sanitary condition and free from any accumulation of rubbish or garbage.			
CONDITION IN VIOLATION trash on 3rd floor fire escape			
LOCATION 3rd floor fire escape			

PHILA. CODE § PM15-304.18		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Doors, windows or hatchways for dwelling units, room units or housekeeping units shall be provided with devices designed to provide security for the occupants and property within.			
CONDITION IN VIOLATION entry door not secure (building)			
LOCATION building door (3140 n 16th)			



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-007006



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 08/12/2021.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: BRUCE WALLACE Bruce.Wallace@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686