



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-036012



DISTRICT OFFICE

Code Enforcement East District
7522 Castor Ave
Philadelphia, PA 19152
215-685-0535
CodeEnforcement.East@phila.gov

PROPERTY IN VIOLATION

4501 N HOWARD ST, Philadelphia, PA 19140-1610

DATE OF NOTICE

05/06/2021

On 05/05/2021 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 06/09/2021

VIOLATIONS

PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
FC-13-915	\$300.00	(QR Code Unavailable)
PHILA. CODE LANGUAGE Property owners are required to have fire suppression, alarm, Emergency/Standby Power, and other emergency electrical systems inspected and certified annually by an individual or company licensed by the Department of Licenses and Inspections. The certification(s) must be kept on site for three years and made available for review F-915		
CONDITION IN VIOLATION POST ON SITE FIRE ALARM SYSTEM CERTIFICATION		
LOCATION 4501 N. HOWARD ST. /WAREHOUSE		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-036012

VIOLATIONS

PHILA. CODE § FC-13-1007.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Exit signs shall be illuminated at all times F-1007.2		
CONDITION IN VIOLATION REPAIR/REPLACE EXIT SIGNS		
LOCATION 4501 N. HOWARD ST/ WAREHOUSE		

PHILA. CODE § FC-13-906.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel. F-906.5		
CONDITION IN VIOLATION MOUNT/ INSTALL EXTINGUISHERS		
LOCATION 4501 N. HOWARD ST/ WAREHOUSE		

PHILA. CODE § FC-13-1008.2.3.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Manually operated flush bolts or surface bolts on means of egress doors are not permitted. F-1008.2.3.2		
CONDITION IN VIOLATION REMOVE BOLT LOCK / PADLOCKS		
LOCATION 4501 N. HOWARD ST/ WAREHOUSE /REAR EXIT DOOR		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-036012

VIOLATIONS

PHILA. CODE § FC-13-2704		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE General Req.- cite code section			
CONDITION IN VIOLATION REMOVE /STORE ADHESIVE MATERIAL IN SECURE ENCLOSED AREA			
LOCATION 4501 N. HOWARD ST/ WAREHOUSE			

PHILA. CODE § FC-13-2703.9.5		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Electrical wiring and/or equipment at this location is improperly installed and/or maintained. Electrical wiring and equipment shall be installed and maintained in accordance with the Philadelphia Electrical Code. You must bring the indicated electrical wiring and/or equipment into compliance with the Philadelphia Electrical Code. F-2703.9			
CONDITION IN VIOLATION REPAIR OPEN SLICING,OPEN JUNCTION BOXES ,HANGING OUTLETS, AND ELECTRICAL WIRING			
LOCATION 4501 N. HOWARD ST/ WAREHOUSE			

PHILA. CODE § FC-13-1008.2.5		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Exit doors must be self closing and latching to prevent smoke intrusion F-1008.2.5			
CONDITION IN VIOLATION REPAIR ALL EXIT DOORS TO BE SELF CLOSING AND FIRE RATED			
LOCATION 4501 N. HOWARD ST/ WAREHOUSE			



✕ Violation Notice and Order to Correct

L&I File Number: CF-2021-036012



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 03/15/2022.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: FRANCINE GRIFFIN Francine.Griffin@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686