



✕ Violation Notice and Order to Correct

L&I File Number: CF-2022-039341



DISTRICT OFFICE

Property Maintenance Unit
5TH FLR
2401 Walnut St
Philadelphia, PA 19103
215-683-0575

PROPERTY IN VIOLATION

150 DEARBORN ST, Philadelphia, PA 19139-2740

DATE OF NOTICE

05/05/2022

On 05/04/2022 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 06/08/2022

VIOLATIONS

PHILA. CODE § PM15-301	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All vacant structures and premises thereof or vacant land shall be maintained in a clean, safe, secure and sanitary condition as provided herein so as not to cause a blighting problem or adversely affect the public health or safety		
CONDITION IN VIOLATION Vacant Property. Open to trespass		
LOCATION 150 Dearborn St		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2022-039341

VIOLATIONS

PHILA. CODE § PM15-302.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All exterior property and premises must be maintained in a clean, safe and sanitary condition and free from any accumulation of rubbish or garbage.		
CONDITION IN VIOLATION Exterior rear yard		
LOCATION 150 Dearborn St		

PHILA. CODE § PM15-302.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All premises and exterior property shall be maintained free from weeds or plant growth in excess of 10" All noxious weeds shall be prohibited. Weeds shall be defined as all grasses, annual plants and vegetation, other than trees or shrubs provided; however, this term shall not include cultivated flowers and gardens. Failure to comply with the notice of violation, any duly authorized employee of the jurisdiction or contractor hired by the jurisdiction shall be authorized to enter upon the property in violation and cut and destroy the weeds growing thereon, and the costs of such removal shall be paid by the owner or agent responsible for the property.		
CONDITION IN VIOLATION Exterior rear yard		
LOCATION 150 Dearborn St		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2022-039341

VIOLATIONS

PHILA. CODE § PM15-304.19V	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Vacant properties shall have doors, windows, and openings from the roof or other areas maintained in good repair. They shall be securely locked, fastened, or otherwise secured. Sealing with boards or masonry or other materials that are not windows with frames and glazing or entry doors shall not constitute good repair or being locked, fastened or otherwise secured.		
CONDITION IN VIOLATION 3 windows and 2 doors		
LOCATION 150 Dearborn St		

PHILA. CODE § PM15-304.12	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.		
CONDITION IN VIOLATION Handrail missing at exterior front steps		
LOCATION 150 Dearborn St		

PHILA. CODE § 9-3906	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The owners of vacant piers, bulkheads, wharves, docks, moored vessels, and other structures that have structural elements partly or totally below water along the shorelines of the Delaware River, Schuylkill River, or estuaries shall obtain a Vacant Waterfront Structure License 9-3906		
CONDITION IN VIOLATION Vacant Property		
LOCATION 150 Dearborn St		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2022-039341



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 07/14/2022.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: GERARDO GONZALEZ Gerardo.Gonzalez@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686