



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-033117



DISTRICT OFFICE

Fire Safety Central West District
3RD FLR
667 N Broad St
Philadelphia, PA 19123
215-685-3917

PROPERTY IN VIOLATION

5941-49 MARKET ST, Philadelphia, PA 19139-3119

DATE OF NOTICE

03/02/2024

On 04/20/2023 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 04/04/2024

VIOLATIONS

PHILA. CODE § F-604.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.		
CONDITION IN VIOLATION Remove improperly used extension cords.		
LOCATION		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-033117

VIOLATIONS

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION Approved extinguishers must be hung in required locations. All extinguishers must be inspected and tagged by an approved company.		
LOCATION		

PHILA. CODE § F-901.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, mechanical smoke exhaust systems and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.		
CONDITION IN VIOLATION Fire alarm panel was showing trouble. Have alarm repaired by an approved company and returned to normal service. Have system heat detectors changed to smoke detectors where there are no products of combustion present.		
LOCATION		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-033117

VIOLATIONS

PHILA. CODE § F-901.6.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The testing of fire protection systems shall be in accordance with Sections 901.6 and F-901.6.4 through F-901.6.4.8.1. Annually the owner of each building that contains fire protection systems shall have such systems certified as operating properly by a person certified or licensed by the Department of Licenses and Inspections to provide such certifications in accordance with this Section. Certification forms shall be maintained on the property and made available for inspection upon the request of a fire code official. The certification form shall be submitted to the Department of Licenses and Inspections which may, by regulation, establish a fee to be paid upon submission of the form.		
CONDITION IN VIOLATION Once fire alarm is repaired have alarm inspected and certified by an a approved company.		
LOCATION		

PHILA. CODE § F-901.6.4.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The Department of Licenses and Inspections is authorized to require that certification forms be submitted to the Department electronically by the company that performed the certification.		
CONDITION IN VIOLATION Contractor must upload certifications to the Department's website.		
LOCATION		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-033117

VIOLATIONS

PHILA. CODE § F-1104.32	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The security grilles in buildings shall be secured in the full-open position during the period of occupancy by the general public. When a building is occupied, but not by the general public, security grilles are permitted to be in the closed position provided they are openable from the inside without the use of a key or special knowledge or effort.		
CONDITION IN VIOLATION East side exit must be open and available for use when store is open.		
LOCATION		

PHILA. CODE § F-1031.4	FINE AMOUNT \$1,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Exit signs shall be installed and maintained in accordance with the building code that was in effect at the time of construction and the applicable provisions in Section 1104. Decorations, furnishings, equipment or adjacent signage that impairs the visibility of exit signs, creates confusion or prevents identification of the exit shall not be allowed.		
CONDITION IN VIOLATION Repair all non working exit signs.		
LOCATION		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-033117

VIOLATIONS

PHILA. CODE § F-604.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A working space of not less than 30 inches (762 mm) in width, 36 inches (914 mm) in depth and 78 inches (1981 mm) in height shall be provided in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches (762 mm), the working space shall be not less than the width of the equipment. Storage of materials shall not be located within the designated working space.		
CONDITION IN VIOLATION Must remove all storage around electrical panels and fire alarm panel.		
LOCATION 1st floor east side.		

PHILA. CODE § F-1031.10.1	FINE AMOUNT \$1,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.		
CONDITION IN VIOLATION Have emergency lights tested and have record of the test.		
LOCATION		

PHILA. CODE § F-5303.5.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity.		
CONDITION IN VIOLATION Cylinders must be properly secured in store room.		
LOCATION west side		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-033117

VIOLATIONS

PHILA. CODE § F-604.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.		
CONDITION IN VIOLATION Light on 2nd floor must be properly installed.		
LOCATION 2nd floor east store room.		

PHILA. CODE § F-305.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A clearance of at least 3 feet (914 mm) or greater where required by another section of this code or the manufacturer's instructions, between ignition sources, such as luminaires, heaters, flameproducing devices and combustible materials, shall be maintained in an approved manner.		
CONDITION IN VIOLATION remove storage near heater.		
LOCATION 1st floor east store room		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-033117



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 04/01/2024.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: BRYAN CONAWAY Bryan.Conaway@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686