



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-096406



DISTRICT OFFICE

Property Maintenance Unit
5TH FLR
2401 Walnut St
Philadelphia, PA 19103
215-683-0575

PROPERTY IN VIOLATION

2553 BELLFORD ST, Philadelphia, PA 19153-1410

DATE OF NOTICE

09/20/2023

On 09/18/2023 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 10/24/2023

VIOLATIONS

PHILA. CODE § PM15-109.1	FINE AMOUNT \$2,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The Department has deemed the structure referenced in this order Unfit. A structure is unfit for human occupancy whenever the code official finds that such structure is unsafe, unlawful or, because of the degree to which the structure is in disrepair or lacks maintenance, is unsanitary, vermin or rat infested, contains filth and contamination, or lacks ventilation, illumination, sanitary or heating facilities or other essential equipment required by this code, or because the location of the structure constitutes a hazard to the occupants of the structure or to the public. The owner shall be prohibited from admitting any new tenants to any tenant space within such dwelling for the duration of such unfit designation.		
CONDITION IN VIOLATION Have electric restored back to property legally by city entity. PECO		
LOCATION 2553 Bellford st		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-096406

VIOLATIONS

PHILA. CODE § PM15-604.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The electrical system at the premises constitutes a hazard to the occupants due to one or more of the following: inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the defects must be corrected to eliminate the hazard.		
CONDITION IN VIOLATION Have electric restored to property legally by city entity. PECO		
LOCATION 2553 Bellford st		

PHILA. CODE § PM15-604.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every occupied building shall be provided with an electrical system in compliance with the requirements of this code.		
CONDITION IN VIOLATION Have electric restored to property legally by city entity. PECO		
LOCATION 2553 Bellford st		

PHILA. CODE § F-313.1.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The fire code official is authorized to require removal of fueled equipment from locations where the presence of such equipment is determined by the fire code official to be hazardous.		
CONDITION IN VIOLATION Remove gas cans from the front of the property		
LOCATION 2553 Bellford st		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-096406

VIOLATIONS

PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
F-505.1	\$300.00	
PHILA. CODE LANGUAGE New and existing buildings shall be provided with approved address identification. The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall not be spelled out. Each character shall be not less than 4 inches (102 mm) high with a minimum stroke width of 1/2 inch (12.7 mm). Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address identification shall be maintained.		
CONDITION IN VIOLATION No address identification		
LOCATION 2553 Bellford st		

PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
F-604.1	\$300.00	
PHILA. CODE LANGUAGE Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible code official. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.		
CONDITION IN VIOLATION Meter head removed from meter bank		
LOCATION 2553 Bellford st		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-096406

VIOLATIONS

PHILA. CODE § PM15-307	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every exterior and interior flight of stairs having more than four risers shall have a handrail on one side of the stair and every open portion of a stair, landing, balcony, porch, deck, ramp or other walking surface which is more than 30 inches (762 mm) above the floor or grade below shall have guards. Handrails shall not be less than 30 inches (762 mm) high or more than 42 inches (1067 mm) high measured vertically above the nosing of the tread or above the finished floor of the landing or walking surfaces. Guards shall not be less than 30 inches (762 mm) high above the floor of the landing, balcony, porch, deck, or ramp or other walking surface.		
CONDITION IN VIOLATION Missing handrail in front of property		
LOCATION 2553 Bellford st		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



✕ Violation Notice and Order to Correct

L&I File Number: CF-2023-096406



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 12/11/2023.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: AEISHA BATTLE AEisha.Battle@Phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686