



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-024970



DISTRICT OFFICE

Fire Safety East District
3RD FLR
667 N Broad St
Philadelphia, PA 19123
215-685-3917

PROPERTY IN VIOLATION

5515-21 N 6TH ST, Philadelphia, PA 19120-2706

DATE OF NOTICE

03/28/2024

On 03/27/2024 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 05/01/2024

VIOLATIONS

PHILA. CODE § F-105.6.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A license is required for operation of repair garages and automotive, marine and fleet motor fuel-dispensing facilities. This license shall be inclusive of the storage of hazardous materials (F-105.6.9) and cutting and welding operations (F-105.6.7) such that those additional licenses shall not also be required.		
CONDITION IN VIOLATION NO CURRENT AUTO REPAIR LICENSE FOUND.		
LOCATION 5515-21 N. 6TH ST		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-024970

VIOLATIONS

PHILA. CODE § F-105.6.1.8	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A hazardous materials license is required to store, transport on site, dispense, use or handle hazardous materials in excess of the amounts listed in Table F-105.6.1.8 and for extremely hazardous substances in accordance with Section F-105.6.8.		
CONDITION IN VIOLATION NO HAZARDOUS MATERIALS LICENSE FOUND.		
LOCATION 5515-21 N. 6TH ST		

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION FIRE EXTINGUISHERS NEED CURRENT INSPECTION TAGS.		
LOCATION 5515-21 N. 6TH ST		

PHILA. CODE § F-2403.4.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Approved metal waste cans equipped with self-closing lids shall be provided wherever rags or waste are impregnated with finishing material. Such rags and waste shall be deposited therein immediately after being utilized. The contents of waste cans shall be properly disposed of not less than once daily and at the end of each shift.		
CONDITION IN VIOLATION SELF CLOSING CAN FOR OILY RAGS NEEDED.		
LOCATION 5515-21 N. 6TH ST		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-024970

VIOLATIONS

PHILA. CODE § F-904.5.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Systems shall be inspected and tested for proper operation at six-month intervals. Tests shall include a check of the detection system, alarms and releasing devices, including manual stations and other associated equipment. Extinguishing system units shall be weighed and the required amount of agent verified. Stored pressure type units shall be checked for the required pressure. The cartridge of cartridge-operated units shall be weighed and replaced at intervals indicated by the manufacturer.		
CONDITION IN VIOLATION NO CURRENT CERTIFICATION FOR PAINT/SPRAY BOOTH. CERTIFICATION MUST BE UPLOADED TO THE CITY OF PHILADELPHIA ECLIPSE SYSTEM.		
LOCATION 5515-21 N 6TH ST		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-024970



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 07/18/2024.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: KERRY WITHERS Kerry.Withers@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686