



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-057365



DISTRICT OFFICE

PROPERTY IN VIOLATION

5251 D ST, Philadelphia, PA 19120-3616

DATE OF NOTICE

06/07/2024

On 06/05/2024 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 07/11/2024

VIOLATIONS

PHILA. CODE § 9-3902 (1)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The owner of any one or two -family dwelling let for occupancy must obtain a rental license. No person shall collect rent with respect to any property that is required to be licensed pursuant to this Section unless a valid rental license has been issued for the property. 9-3902		
CONDITION IN VIOLATION The owner of the property must obtain the required rental license		
LOCATION 5251 D St		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-057365

VIOLATIONS

PHILA. CODE § F-1103.9	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Carbon monoxide alarms shall be installed in existing dwelling units or sleeping units in accordance with Sections F-1103.9.1 through F-1103.9.3 where any of the conditions in Sections 915.1.2 through 915.1.6 exist. A carbon monoxide detection system installed in accordance with Section 915.5 shall be an acceptable alternative to carbon monoxide alarms.		
CONDITION IN VIOLATION Install CO detector		
LOCATION 5251 D St/ Apt 2nd Flr/ Sleeping Area		

PHILA. CODE § PM15-305.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking or abraded paint shall be repaired, removed or covered. Cracked or loose plaster, decayed wood and other defective surface conditions shall be corrected.		
CONDITION IN VIOLATION Repair cracks/ chipping paint in walls and ceilings		
LOCATION 5251 D St/ Apt 2nd floor/ Bedrooms/Hallway		

PHILA. CODE § PM15-305.1(e)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Stairs, landings, balconies and all similar walking surfaces, including guards and handrails, are not structurally sound, not properly anchored or are anchored with connections not capable of supporting all nominal loads and resisting all load effects.		
CONDITION IN VIOLATION Remove or secure carpet on stairwell/ replace or repair damaged floor tile		
LOCATION 5251 D St/ Apt 2nd Floor/ Stairwell ,Basement		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-057365

VIOLATIONS

PHILA. CODE § PM15-304.15	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All exterior doors, door assemblies and hardware shall be maintained in good condition. Locks at all entrances to dwelling units and sleeping units shall tightly secure the door. Locks on means of egress doors shall be in accordance with Chapter 10 of the Philadelphia Fire Code.		
CONDITION IN VIOLATION Replace double-key lock with thumb-turn Tumblr		
LOCATION 5251 D St/ Exterior Front Entry Door		

PHILA. CODE § F-304.1.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Weeds, grass, vines or other growth that is capable of being ignited and endangering property, shall be cut down and removed by the owner or occupant of the premises. Vegetation clearance requirements in urban-wildland interface areas shall be in accordance with the International Wildland-Urban Interface Code.		
CONDITION IN VIOLATION Remove excessive weeds and vegetation		
LOCATION 5251 D St/ Exterior Rear		

PHILA. CODE § PM15-304.13	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All glazing materials shall be maintained free from cracks and holes and shall be easily openable and capable of being held in position by window hardware.		
CONDITION IN VIOLATION Replace glazing in window		
LOCATION 5251 D St/ Apt 2nd Floor/ Bedroom		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-057365

VIOLATIONS

PHILA. CODE § F-1103.8	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Single- and multiple-station (single-station wired together to enable all to sound an alarm when one activates) smoke alarms shall be installed in existing Group R occupancies in accordance with Sections F-1103.8.1 through F-1103.8.3.		
CONDITION IN VIOLATION Install smoke detector		
LOCATION 5251 D St/ Apt 2nd Floor/ Sleeping Area		

PHILA. CODE § F-304.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Storage of combustible rubbish shall not produce conditions that will create a nuisance or a hazard to the public health, safety or welfare.		
CONDITION IN VIOLATION Remove paint cans, personal storage inside doorway egress exit		
LOCATION 5251 D St / Entry Common area		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-057365



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 07/07/2024.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: WILLIAM CORLEY JR. William.CorleyJr@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686