



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810



DISTRICT OFFICE

Code Enforcement South District
2ND FLR
1100 Wharton St
Philadelphia, PA 19147
215-685-1510
CodeEnforcement.South@phila.gov

PROPERTY IN VIOLATION

1800-10 S 23RD ST, Philadelphia, PA 19145-1834

DATE OF NOTICE

10/29/2024

On 10/28/2024 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 12/02/2024

VIOLATIONS

PHILA. CODE § 6-301(4)(b)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Retail food establishments with permanent location, including, but not limited to candy stores and drug stores without soda fountains, grocery, meat markets, and other food stores.		
CONDITION IN VIOLATION OBTAIN FOOD LICENSE #3120 FOR J & E FOOD MARKET		
LOCATION (J & E FOOD MARKET)		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810

VIOLATIONS

PHILA. CODE § 9-1405(1)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE No person shall operate or maintain a weighing or measuring device for commercial purposes unless he or she has registered the business utilizing the device with the Department.		
CONDITION IN VIOLATION OBTAIN SCALES & SCANNER LICENSE #3822 FOR J & E FOOD MARKET		
LOCATION (J & E FOOD MARKET)		

PHILA. CODE § F-901.6.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The testing of fire protection systems shall be in accordance with Sections 901.6 and F-901.6.4 through F-901.6.4.8.1. Annually the owner of each building that contains fire protection systems shall have such systems certified as operating properly by a person certified or licensed by the Department of Licenses and Inspections to provide such certifications in accordance with this Section. Certification forms shall be maintained on the property and made available for inspection upon the request of a fire code official. The certification form shall be submitted to the Department of Licenses and Inspections which may, by regulation, establish a fee to be paid upon submission of the form.		
CONDITION IN VIOLATION PROVIDE CURRENT FIRE ALARM CERTIFICATION AND HAVE LICENSED CONTRACTOR UPLOAD INTO THE ECLIPSE PORTAL		
LOCATION 1800-10 S 23RD ST		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810

VIOLATIONS

PHILA. CODE § F-904.12.5.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.		
CONDITION IN VIOLATION PROVIDE CURRENT KITCHEN HOOD SPECIAL HAZARDS CERTIFICATION AND HAVE LICENSED CONTRACTOR UPLOAD INTO THE ECLIPSE PORTAL		
LOCATION (J & E FOOD MARKET)		

PHILA. CODE § A-301.1/65	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A use registration permit is required for every new use commenced on any land or in any structure. Return the subject premise to its approved usage or secure the proper permit for its present use.		
CONDITION IN VIOLATION OBTAIN ZONING / USE PERMIT FOR DOMINICAN BEAUTY SALON OR RETURN BACK TO LAST APPROVED USE AS VACANT		
LOCATION (NAYLA DOMINICAN BEAUTY SALON) AKA 1797 POINT BREEZE AVE		

PHILA. CODE § A-701.1/1	FINE AMOUNT \$2,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A violation has been issued because the building, portion of the building, or premises is occupied prior to departmental approval or issuance of the Certificate of Occupancy or Temporary Certificate of Occupancy.		
CONDITION IN VIOLATION OBTAIN CERTIFICATE OF OCCUPANCY FOR J & E FOOD MARKET		
LOCATION (J & E FOOD MARKET)		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810

VIOLATIONS

PHILA. CODE § F-907.8.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Where required for compliance with the provisions of this code, devices, equipment, systems, conditions, arrangements, levels of protection or other features shall thereafter be continuously maintained in accordance with applicable NFPA requirements or as directed by the fire code official.		
CONDITION IN VIOLATION REPAIR FIRE ALARM SYSTEM, STATES FIRE ALARM SILENCED		
LOCATION 1800-10 S 23RD ST		

PHILA. CODE § F-305.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A clearance of at least 3 feet (914 mm) or greater where required by another section of this code or the manufacturer's instructions, between ignition sources, such as luminaires, heaters, flameproducing devices and combustible materials, shall be maintained in an approved manner.		
CONDITION IN VIOLATION REMOVE SHOPPING CART, BUCKETS, CAR SEAT AND ALL OTHER ITEMS ON HOT WATER TANK		
LOCATION (J & E FOOD MARKET) REAR		

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION HAVE ALL EXPIRED FIRE EXTINGUISHERS INSPECTED & TAGGED WITH CURRENT YEAR		
LOCATION (J & E FOOD MARKET) FRONT & REAR		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810

VIOLATIONS

PHILA. CODE § F-906.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall not be obstructed or obscured from view. In rooms or areas in which visual obstruction cannot be completely avoided, means shall be provided to indicate the locations of extinguishers.		
CONDITION IN VIOLATION REMOVE LADDER FROM IN FRONT OF FIRE EXTINGUISHER		
LOCATION (J & E FOOD MARKET) REAR SIDE		

PHILA. CODE § F-906.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Fire extinguishers provided for the protection of cooking equipment shall be of an approved type compatible with the automatic fire-extinguishing system agent. Cooking equipment involving solid fuels or vegetable or animal oils and fats shall be protected by a Class K-rated portable extinguisher in accordance with Sections 906.1, Item 2, 906.4.1 and 906.4.2 as applicable.		
CONDITION IN VIOLATION INSTALL / MOUNT INSPECTED & TAGGED CLASS K FIRE EXTINGUISHER		
LOCATION (J & E FOOD MARKET) KITCHEN		

PHILA. CODE § A-701.1/1	FINE AMOUNT \$2,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A violation has been issued because the building, portion of the building, or premises is occupied prior to departmental approval or issuance of the Certificate of Occupancy or Temporary Certificate of Occupancy.		
CONDITION IN VIOLATION OBTAIN CERTIFICATE OF OCCUPANCY FOR DOMINICAN BEAUTY SALON		
LOCATION (NAYLA DOMINICAN BEAUTY SALON) AKA 1797 POINT BREEZE AVE		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810

VIOLATIONS

PHILA. CODE § F-604.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.		
CONDITION IN VIOLATION REMOVE EXTENSION CORDS AND PLUG DIRECTLY INTO OUTLET		
LOCATION (J & E FOOD MARKET) BEHIND COUNTER		

PHILA. CODE § F-604.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with NFPA 70 shall be prohibited.		
CONDITION IN VIOLATION REMOVE MULTIPLUG ADAPTORS AND POWERSTRIPS AND PLUG DIRECTLY INTO OUTLET		
LOCATION (J & E FOOD MARKET) BEHIND COUNTER		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810

VIOLATIONS

PHILA. CODE § F-701.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The fire-resistance rating of the following fire-resistance-rated construction shall be maintained: 1. Structural members. 2. Exterior walls. 3. Fire walls, fire barriers, fire partitions. 4. Horizontal assemblies. 5. Shaft enclosures.		
CONDITION IN VIOLATION FIX CEILING TILE TO MAINTAIN FIRE RESISTANCE CONSTRUCTION		
LOCATION (J & E FOOD MARKET) ABOVE ANSUL SYSTEM		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 02/03/2025.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



Department of Licenses and Inspections
City of Philadelphia

✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-114810



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: YOLONDA TOLBERT Yolonda.Tolbert@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیے: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686

