



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-121563



DISTRICT OFFICE

Business Compliance Unit
5TH FLR
2401 Walnut St
Philadelphia, PA 19103
215-686-2414

PROPERTY IN VIOLATION

6151 MARKET ST, Philadelphia, PA 19139-3031

DATE OF NOTICE

11/21/2024

On 11/20/2024 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 12/25/2024

VIOLATIONS

PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
F-1103.7.11	\$300.00	
PHILA. CODE LANGUAGE Where a nonresidential occupancy is located below a residential occupancy, a manual and automatic (smoke detection) fire alarm system shall be installed with smoke detectors installed throughout the nonresidential occupancy, manual fire alarm boxes installed at the exits in the nonresidential areas and alarm notification appliances installed throughout the building. Smoke alarms shall be installed in the dwelling units of the residential portions of the building in accordance with Section F-1103.8.		
CONDITION IN VIOLATION MUST HAVE LICENSED CONTRACTOR INSTALL REQUIRED FIRE ALARM SYSTEM.		
LOCATION 6151 MARKET ST		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-121563

VIOLATIONS

PHILA. CODE § F-901.6.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The testing of fire protection systems shall be in accordance with Sections 901.6 and F-901.6.4 through F-901.6.4.8.1. Annually the owner of each building that contains fire protection systems shall have such systems certified as operating properly by a person certified or licensed by the Department of Licenses and Inspections to provide such certifications in accordance with this Section. Certification forms shall be maintained on the property and made available for inspection upon the request of a fire code official. The certification form shall be submitted to the Department of Licenses and Inspections which may, by regulation, establish a fee to be paid upon submission of the form.		
CONDITION IN VIOLATION HAVE A LICENSED CONTRACTOR UPLOAD FIRE ALARM CERTIFICATION TO THE ECLIPSE PORTAL ONCE INSTALLED.		
LOCATION 6151 MARKET ST		

PHILA. CODE § A-301.1/65	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A use registration permit is required for every new use commenced on any land or in any structure. Return the subject premise to its approved usage or secure the proper permit for its present use.		
CONDITION IN VIOLATION MUST REGISTER NEW USE (PERSONAL SERVICE HAIR SALON) WITH THE DEPARTMENT OR RETURN PROEPTY TO ITS LAST APPROVED USE (RETAIL SALES/FOOD, BEVERAGES, & GROCERIES).		
LOCATION 6151 MARKET ST		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-121563

VIOLATIONS

PHILA. CODE § A-301.1/66	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A violation has been issued because the building, sign or other advertising structure or device is erected altered, used or maintained in violation of Chapter 14 -2000 of the Zoning Code. If the condition is not corrected by the removal of the structure, sign or device or the cessation of the use, or by obtaining the proper approval within 10 days of this notice, the department either directly or through contractor, will remove the structure, sign or device. You, as the owner, will be billed for the expenses incurred to correct the violation. The city will enforce payment of the bill or further proceed to record liens and take other actions as the law allows to affect collection of the bills related to its corrective actions.		
CONDITION IN VIOLATION MUST OBTAIN A ZONING PERMIT FOR THE ADVERTISING SIGN THAT WAS INSTALLED ON THE PREMISE.		
LOCATION 6151 MARKET ST		

PHILA. CODE § F-604.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.		
CONDITION IN VIOLATION SEAL/COVER ALL OPEN JUNCTION BOXES IN THE BASEMENT		
LOCATION 6151 MARKET ST		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-121563

VIOLATIONS

PHILA. CODE § F-906.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be installed in all of the following locations: 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. 2. Within 30 feet (9144 mm) distance of travel from commercial cooking equipment and from domestic cooking equipment in Group I-1; I-2, Condition 1; and R-2 college dormitory occupancies. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 3315.1. 5. Where required by the sections indicated in Table 906.1. 6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.		
CONDITION IN VIOLATION INSTALLL APPROVED ABC FIRE EXTINGUISHERS		
LOCATION 6151 MARKET ST - COMMERCIAL SPACE & BASEMENT		

PHILA. CODE § F-906.7	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Hand-held portable fire extinguishers, not housed in cabinets, shall be installed on the hangers or brackets supplied. Hangers or brackets shall be securely anchored to the mounting surface in accordance with the manufacturer's installation instructions.		
CONDITION IN VIOLATION FIRE EXTINGUISHERS MUST BE MOUNTED TO BRACKETS OR HOUSED WITHIN APPROVED CABINETS		
LOCATION 6151 MARKET ST		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-121563

VIOLATIONS

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION FIRE EXTINGUISHERS MUST BE INSPECTED AND TAGGED		
LOCATION 6151 MARKET ST		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 01/30/2025.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



Department of Licenses and Inspections
City of Philadelphia

✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-121563



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: Francheska Sanchez Francheska.Sanchez@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیے: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686

