



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-123980



DISTRICT OFFICE

Business Compliance Unit
5TH FLR
2401 Walnut St
Philadelphia, PA 19103
215-686-2414

PROPERTY IN VIOLATION

718 S 52ND ST, Philadelphia, PA 19143-2612

DATE OF NOTICE

12/04/2024

On 12/02/2024 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 01/07/2025

VIOLATIONS

PHILA. CODE § F-907.8.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The building owner shall be responsible to maintain the fire and life safety systems in an operable condition at all times. Service personnel shall meet the qualification requirements of NFPA 72 for inspection, testing and maintenance of such systems. Records of inspection, testing and maintenance shall be maintained.		
CONDITION IN VIOLATION REPAIR INOPERABLE FIRE ALARM SYSTEM		
LOCATION 716-18 S 52ND ST		





✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-123980

VIOLATIONS

PHILA. CODE § F-901.6.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The testing of fire protection systems shall be in accordance with Sections 901.6 and F-901.6.4 through F-901.6.4.8.1. Annually the owner of each building that contains fire protection systems shall have such systems certified as operating properly by a person certified or licensed by the Department of Licenses and Inspections to provide such certifications in accordance with this Section. Certification forms shall be maintained on the property and made available for inspection upon the request of a fire code official. The certification form shall be submitted to the Department of Licenses and Inspections which may, by regulation, establish a fee to be paid upon submission of the form.		
CONDITION IN VIOLATION UPLOAD FIRE ALARM CERTIFICATION INTO ECLIPSE SYSTEM		
LOCATION 716-18 S 52ND ST		

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION SERVICE AND UPDATE TAGS ON ALL FIRE EXTINGUISHERS		
LOCATION 716-18 S 52ND ST/ SHERWOOD BEER DISTRIBUTORS		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-123980

VIOLATIONS

PHILA. CODE § A-301.1/66	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A violation has been issued because the building, sign or other advertising structure or device is erected altered, used or maintained in violation of Chapter 14 -2000 of the Zoning Code. If the condition is not corrected by the removal of the structure, sign or device or the cessation of the use, or by obtaining the proper approval within 10 days of this notice, the department either directly or through contractor, will remove the structure, sign or device. You, as the owner, will be billed for the expenses incurred to correct the violation. The city will enforce payment of the bill or further proceed to record liens and take other actions as the law allows to affect collection of the bills related to its corrective actions.		
CONDITION IN VIOLATION REMOVE 80% OF ADVERTISING COVERING STORE WINDOWS AND DOORS		
LOCATION 716-18 S 52ND ST/ SHERWOOD BEER DISTRIBUTORS -EXTERIOR FRONT		

PHILA. CODE § PM15-304.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent deterioration.		
CONDITION IN VIOLATION COVER HOLE OR REPLACE BRICKS/WOODS IN WALL		
LOCATION 716-18 S 52ND ST/ SHERWOOD BEER DISTRIBUTORS- EXTERIOR FRONT		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-123980

VIOLATIONS

PHILA. CODE § 6-301(4)(a)(.2)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE For food establishments with permanent location where the primary business is the regular and customary preparation and sale of food for consumption on or off the premises, including but not limited to, eating and drinking establishments and caterers. For establishments that do not have thirty or more seats regularly available for and accessible to customers to consume food on the premises.		
CONDITION IN VIOLATION OBTAIN REQUIRED FOOD LICENSE		
LOCATION 716-18 S 52ND ST/ SHERWOOD BEER DISTRIBUTORS		

PHILA. CODE § F-604.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.		
CONDITION IN VIOLATION EXTENSION CORDS / MULTI-PLUG AND POWER-STRIPS CANNOT BE USED AS PERMANANET OUTLETS INSTALL EXTRA WALL OUTLETS		
LOCATION 716-18 S 52ND ST/ SHERWOOD BEER DISTRIBUTORS/ INTERIOR NEAR MACHINES		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-123980

VIOLATIONS

PHILA. CODE § F-1105.5.4.2.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Where self- or automatic-closing doors are required, closers shall be maintained in operational condition.		
CONDITION IN VIOLATION REPAIR DOOR LOCK AND MAKE ALL EXIT DOORS SELF CLOSING		
LOCATION 716-18 S 52ND ST/ SHERWOOD BEER DISTRIBUTORS		

PHILA. CODE § F-1104.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Exit signs shall be internally or externally illuminated. The face of an exit sign illuminated from an external source shall have an intensity of not less than 5 foot-candles (54 lux). Internally illuminated signs shall provide equivalent luminance and be listed for the purpose.		
CONDITION IN VIOLATION INSTALL ILLUMINATED EXIT SIGN		
LOCATION 716-18 S 52ND ST/ FRONT EXIT DOOR AREA		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



✕ Violation Notice and Order to Correct

L&I File Number: CF-2024-123980



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 02/08/2025.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: WILLIAM CORLEY JR. William.CorleyJr@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686