



Violation Notice and Order to Correct

L&I File Number: CF-2025-008380

V5



DISTRICT OFFICE

Property Maintenance Unit
5TH FLR
2401 Walnut St
Philadelphia, PA 19103
215-683-0575

PROPERTY IN VIOLATION

2548 S 58TH ST, Philadelphia, PA 19143-6116

DATE OF NOTICE

02/07/2025

On 02/06/2025 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) which violate the Philadelphia Code. Based on all or some of these Code Violations the property is deemed:

UNFIT/A PUBLIC NUISANCE

The property will remain in this status until all the necessary violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

The Department of Licenses and Inspections hereby certifies that the violations at this property create a condition of immediate danger or hazard to health safety and welfare which requires immediate compliance and/or are intentional.

If these violations are not corrected before 02/19/2025 the Department will issue a Cease Operations Order requiring the property to be vacated that same day.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE REPAIRS AND/OR TAKE NECESSARY ACTION TO CORRECT THE CITED CONDITIONS PRIOR TO 02/19/2025

VIOLATIONS



✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-008380

VIOLATIONS

PHILA. CODE § PM15-109.1	FINE AMOUNT \$2,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The Department has deemed the structure referenced in this order Unfit. A structure is unfit for human occupancy whenever the code official finds that such structure is unsafe, unlawful or, because of the degree to which the structure is in disrepair or lacks maintenance, is unsanitary, vermin or rat infested, contains filth and contamination, or lacks ventilation, illumination, sanitary or heating facilities or other essential equipment required by this code, or because the location of the structure constitutes a hazard to the occupants of the structure or to the public. The owner shall be prohibited from admitting any new tenants to any tenant space within such dwelling for the duration of such unfit designation.		
CONDITION IN VIOLATION Repair heating		
LOCATION 2nd floor		

PHILA. CODE § PM15-602.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Heat shall be supplied continuously at the temperature and in the rooms specified in Section PM-602.2 from October 1 to April 30 inclusive, and in addition thereto during the months of May or September when the outside temperature falls below 60 degrees F (15 degrees C) by every owner or operator of every two-family dwelling, multiple-family dwelling and rooming house except where there are separate heating facilities for each dwelling unit, whose facilities are under the sole control of the occupant of such dwelling unit		
CONDITION IN VIOLATION Repair heating		
LOCATION 2nd floor		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-008380

VIOLATIONS

PHILA. CODE § PM15-603.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All mechanical appliances, fireplaces, solid fuel-burning appliances, cooking appliances and water heating appliances shall be properly installed and maintained in a safe working condition, and shall be capable of performing the intended function.		
CONDITION IN VIOLATION Repair heating		
LOCATION 2nd floor		

PHILA. CODE § PM15-304.15	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All exterior doors, door assemblies and hardware shall be maintained in good condition. Locks at all entrances to dwelling units and sleeping units shall tightly secure the door. Locks on means of egress doors shall be in accordance with Chapter 10 of the Philadelphia Fire Code.		
CONDITION IN VIOLATION Entrance door must be weathertight		
LOCATION apt 2		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in:

- The removal of all occupants and a Cease Operations Order being imposed;
- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-008380



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 03/09/2025.

Appeal of this Notice does not extend the time for you to comply nor will it stop any action by the City of Philadelphia.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Preventions. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: SHAWN HOWARD Shawn.Howard@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیے: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686