

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-023842



DISTRICT OFFICE

Nuisance Property Unit
5TH FLR
2401 Walnut St
Philadelphia, PA 19103
215-686-2515
NuisancePropertyUnit@phila.gov

PROPERTY IN VIOLATION

340 N 41ST ST, Philadelphia, PA 19104-2234

DATE OF NOTICE

04/03/2025

On 04/01/2025 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 05/07/2025

VIOLATIONS

PHILA. CODE § A-301.1/65	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A use registration permit is required for every new use commenced on any land or in any structure. Return the subject premise to its approved usage or secure the proper permit for its present use.		
CONDITION IN VIOLATION ALL DRUG PARAPHERNALIA SHALL BE REMOVED FROM PROPERTY (CEASE THE SALE OF DRUG PARAPHERNALIA)		
LOCATION 340 N 41ST ST		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-023842

VIOLATIONS

PHILA. CODE § 9-1405(1)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE No person shall operate or maintain a weighing or measuring device for commercial purposes unless he or she has registered the business utilizing the device with the Department.		
CONDITION IN VIOLATION OBTAIN/RENEW/DISPLAY SCALES AND SCANNERS LICENSE		
LOCATION 340 N 41ST ST		

PHILA. CODE § F-906.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The size and distribution of portable fire extinguishers shall be in accordance with Sections 906.3.1 through 906.3.4.		
CONDITION IN VIOLATION 2-A-10-B-C SIZED FIRE EXTINGUISHERS ARE REQUIRED		
LOCATION 340 N 41ST ST (COMMERCIAL SPACE AND BASEMENT)		

PHILA. CODE § A-301.1/66	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A violation has been issued because the building, sign or other advertising structure or device is erected altered, used or maintained in violation of Chapter 14 -2000 of the Zoning Code. If the condition is not corrected by the removal of the structure, sign or device or the cessation of the use, or by obtaining the proper approval within 10 days of this notice, the department either directly or through contractor, will remove the structure, sign or device. You, as the owner, will be billed for the expenses incurred to correct the violation. The city will enforce payment of the bill or further proceed to record liens and take other actions as the law allows to affect collection of the bills related to its corrective actions.		
CONDITION IN VIOLATION OBTAIN ZONING FOR AWNING SIGNAGE		
LOCATION 340 N 41ST ST		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-023842

VIOLATIONS

PHILA. CODE § 14-904(1)(i)(.1)	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Window signs shall be limited to the ground floor, except that in CMX-2, CMX-2.5, CMX-3, CMX-4, CMX-5, CA-1, and CA-2 districts, window signs for businesses that are not located on the ground floor shall also be permitted in second floor windows. The total area of signs placed within a window or transparent glass door shall not exceed twenty percent (20%) of the total transparent glazed area of the window or transparent glass door within which they are placed, as defined in 14-203 (Definitions).		
CONDITION IN VIOLATION WINDOW SIGNAGE SHALL NOT BE MORE THANT 20% COVERAGE		
LOCATION 340 N 41ST ST		
PHILA. CODE § F-1031.4	FINE AMOUNT \$1,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Exit signs shall be installed and maintained in accordance with the building code that was in effect at the time of construction and the applicable provisions in Section 1104. Decorations, furnishings, equipment or adjacent signage that impairs the visibility of exit signs, creates confusion or prevents identification of the exit shall not be allowed.		
CONDITION IN VIOLATION ITEMS OBSTRUCTING EXIT SIGNAGE SHALL BE REMOVED		
LOCATION 340 N 41ST ST (FRONT EXIT)		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-023842

VIOLATIONS

PHILA. CODE § F-901.7.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE A tag shall be used to indicate that a system, or portion thereof, has been removed from service.		
CONDITION IN VIOLATION A TAG SHALL BE PROVIDED BY A LICENSED CONTRACTOR STATING THAT THE SUPPRESSION SYSTEM FOR THE KITCHEN HOOD IS NO LONGER IN SERVICE		
LOCATION 340 N 41ST ST		

PHILA. CODE § F-604.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.		
CONDITION IN VIOLATION A PLATE COVER IS REQUIRED FOR THE OPEN WIRE SPLICE		
LOCATION 340 N 41ST ST (1ST FL REAR)_		

PHILA. CODE § F-604.4	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with NFPA 70 shall be prohibited.		
CONDITION IN VIOLATION ALL MULTI-PLUG ADAPTORS SHALL BE REMOVED		
LOCATION 340 N 41ST ST (COMMERCIAL SPACE)		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-023842

VIOLATIONS

PHILA. CODE § F-1013.6.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The face of an exit sign illuminated from an external source shall have an intensity of not less than 5 foot-candles (54 lux).		
CONDITION IN VIOLATION REPAIR INOPERABLE EXIT SIGNAGE		
LOCATION 340 N 41ST ST (FRONT AND REAR EXITS)		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 05/03/2025.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, 11th Floor Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-023842



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: FRANCINE GRIFFIN Francine.Griffin@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیے: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686

