

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983



DISTRICT OFFICE

Fire Safety Central West District
3RD FLR
667 N Broad St
Philadelphia, PA 19123
215-685-3917

PROPERTY IN VIOLATION

11 S 42ND ST, Philadelphia, PA 19104-3078

DATE OF NOTICE

07/01/2025

On 06/25/2025 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 08/04/2025

VIOLATIONS

PHILA. CODE § F-403.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE An approved fire safety and evacuation plan in accordance with Section 404 shall be prepared and maintained for Group E occupancies and for buildings containing both a Group E occupancy and an atrium.		
CONDITION IN VIOLATION PROVIDE FIRE EVACUATION PLANS		
LOCATION PAUL ROBESON HIGH SCHOOL		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983

VIOLATIONS

PHILA. CODE § F-405.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Records shall be maintained of required emergency evacuation drills and include the following information: 1. Identity of the person conducting the drill. 2. Date and time of the drill. 3. Notification method used. 4. Employees on duty and participating. 5. Number of occupants evacuated. 6. Special conditions simulated. 7. Problems encountered.		
CONDITION IN VIOLATION PROVIDE FIRE ALARM DRILL LOG		
LOCATION PAUL ROBESON HIGH SCHOOL		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983

VIOLATIONS

PHILA. CODE § F-404.2.3.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Lockdown plans shall include the following: 1. Identification of individuals authorized to issue a lockdown order. 2. Security measures used during normal operations, when the building is occupied, that could adversely affect egress or fire department operations. 3. A description of identified emergency and security threats addressed by the plan, including specific lockdown procedures to be implemented for each threat condition. 4. Means and methods of initiating a lockdown plan for each threat, including: 4.1. The means of notifying occupants of a lockdown event, which shall be distinct from the fire alarm signal. 4.2. Identification of each door or other access point that will be secured. 4.3. A description of the means or methods used to secure doors and other access points. 4.4. A description of how locking means and methods are in compliance with the requirements of this code for egress and accessibility. 5. Procedures for reporting to the fire department any lockdown condition affecting egress or fire department operations. 6. Procedures for determining and reporting the presence or absence of occupants to emergency response agencies during a lockdown. 7. Means for providing two-way communication between a central location and each area subject to being secured during a lockdown. 8. Identification of the prearranged signal for terminating the lockdown. 9. Identification of individuals authorized to issue a lockdown termination order. 10. Procedures for unlocking doors and verifying that the means of egress has been returned to normal operations upon termination of the lockdown. 11. Training procedures and frequency of lockdown plan drills.		
CONDITION IN VIOLATION PROVIDE SHELTER-IN-PLACE PLAN		
LOCATION PAUL ROBESON HIGH SCHOOL		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983

VIOLATIONS

PHILA. CODE § F-807.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Where required to exhibit improved fire performance, curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall be tested by an approved agency and meet the flame propagation performance criteria of Test Method 1 or Test Method 2, as appropriate, of NFPA 701 or exhibit a maximum rate of heat release of 100 kW when tested in accordance with NFPA 289, using the 20 kW ignition source. Reports of test results shall be prepared in accordance with the test method used and furnished to the fire code official upon request.		
CONDITION IN VIOLATION PROVIDE FIRE RETARDANT DOCUMENTATION FOR WINDOW CURTAINS		
LOCATION PAUL ROBESON HIGH SCHOOL (AUDITORIUM)		
PHILA. CODE § F-1104.28	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Exit doors in existing buildings shall be self-closing and latching and in accordance with Sections F-1104.28.1 and F-1104.28.2		
CONDITION IN VIOLATION REPAIR ALL EXIT DOORS TO SELF CLOSE AND LATCH		
LOCATION PAUL ROBESON HIGH SCHOOL (STAIRWAYS) (BOILER ROOM)		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983

VIOLATIONS

PHILA. CODE § F-1004.9	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space, for the intended configurations. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or the owner's authorized agent.		
CONDITION IN VIOLATION PROVIDE LAWFUL OCCUPANCY SIGN		
LOCATION PAUL ROBESON HIGH SCHOOL (AUDITORIUM) (CAFETERIA) (GYM)		

PHILA. CODE § F-904.12.5.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.		
CONDITION IN VIOLATION HAVE KITCHEN HOOD SUPPRESSION SYSTEM CERTIFICATION UPLOADED TO THE ECLIPSE PORTAL BY A LICENSED CONTRACTOR		
LOCATION PAUL ROBESON HIGH SCHOOL (CAFETERIA)		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983

VIOLATIONS

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION HAVE FIRE EXTINGUISHERS INSPECTED AND TAGGED		
LOCATION PAUL ROBESON HIGH SCHOOL (CAFETERIA)		

PHILA. CODE § F-604.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.		
CONDITION IN VIOLATION COVER OPEN JUNCTION BOX		
LOCATION PAUL ROBESON HIGH SCHOOL (AUDITORIUM, NEAR EXIT DOOR)		

PHILA. CODE § F-315.3.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Combustible material shall not be stored in boiler rooms, mechanical rooms, electrical equipment rooms or in fire command centers as specified in Section 508.1.5.		
CONDITION IN VIOLATION REMOVE COMBUSTIBLE STORAGE		
LOCATION PAUL ROBESON HIGH SCHOOL (BOILER ROOM)		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983

VIOLATIONS

PHILA. CODE § F-509.1.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Where required by the fire code official, gas shutoff valves, electric meters, service switches and other utility equipment shall be clearly and legibly marked to identify the unit or space that it serves. Identification shall be made in an approved manner, readily visible and shall be maintained.		
CONDITION IN VIOLATION LABEL EQUIPMENT ROOMS		
LOCATION PAUL ROBESON HIGH SCHOOL (BOILER ROOM)		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-062983



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 07/31/2025.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: PERCY RIGGS percy.j.riggs@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION : Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686