

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-089133



DISTRICT OFFICE

Vacant Property Unit
SUITE 502
2401 Walnut St
Philadelphia, PA 19103
215-686-2414
VacantPropertyUnit@phila.gov

PROPERTY IN VIOLATION

3409 KENSINGTON AVE, Philadelphia, PA 19134-1420

DATE OF NOTICE

08/22/2025

On 08/20/2025 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 09/25/2025

VIOLATIONS

PHILA. CODE § PM15-304.19V	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Vacant properties shall have doors, windows, and openings from the roof or other areas maintained in good repair. They shall be securely locked, fastened, or otherwise secured. Sealing with boards or masonry or other materials that are not windows with frames and glazing or entry doors shall not constitute good repair or being locked, fastened or otherwise secured.		
CONDITION IN VIOLATION repair front window		
LOCATION 1st floor front		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-089133

VIOLATIONS

PHILA. CODE § PM15-901.1		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The owner of a vacant building must keep the property free of garbage and rubbish, maintain doors, windows, and roof openings in good repair, and ensure proper stormwater drainage. Accessible doors and windows must be secured against trespassers. The owner must also take any additional measures required by the code official, using approved materials to prevent unauthorized entry. A vacant building not properly secured is considered unsafe. If the owner fails to seal the premises or address violations within the specified time, the City will seal and secure the property. All associated costs will be billed to the owner and, if unpaid, placed as a lien on the property.			
CONDITION IN VIOLATION 1- boarded window			
LOCATION 1st floor front			

PHILA. CODE § PM15-301		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All vacant structures and premises thereof or vacant land shall be maintained in a clean, safe, secure and sanitary condition as provided herein so as not to cause a blighting problem or adversely affect the public health or safety			
CONDITION IN VIOLATION Maintain vacant property			
LOCATION 3409 Kensington Ave.			

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-089133

VIOLATIONS

PHILA. CODE § 9-3905	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The owner of any structure that lacks the habitual presence of human beings who have a legal right to be on the premises, or at which substantially all lawful business or construction operations or residential occupancy has ceased within the past three (3) months, shall obtain a Vacant Structure License.		
CONDITION IN VIOLATION obtain the required vacant structure license		
LOCATION 3409 Kensington Ave		

PHILA. CODE § PM15-604.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The electrical system at the premises constitutes a hazard to the occupants due to one or more of the following: inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the defects must be corrected to eliminate the hazard.		
CONDITION IN VIOLATION missing electrical flush mount unit		
LOCATION above 1st floor window		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-089133



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 09/21/2025.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: Dorothy Myers Dorothy.Myers@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686