

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-136370



DISTRICT OFFICE

PROPERTY IN VIOLATION

1419-33 W COURTLAND ST, Philadelphia, PA 19140-1120

DATE OF NOTICE

01/10/2026

On 12/23/2025 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 02/13/2026

VIOLATIONS

PHILA. CODE § F-903.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Sprinkler systems shall be tested and maintained in accordance with Section 901.		
CONDITION IN VIOLATION Suppression system certification must be obtained.		
LOCATION Paint booth		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-136370

VIOLATIONS

PHILA. CODE § F-2403.2.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Smoking shall be prohibited in flammable vapor areas and hazardous materials storage rooms associated with flammable finish processes. "No Smoking" signs complying with Section 310 shall be conspicuously posted in such areas.		
CONDITION IN VIOLATION No smoking signs are required		
LOCATION paint mixing areas		

PHILA. CODE § F-604.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.		
CONDITION IN VIOLATION Any and all light switches and outlet covers must be installed.		
LOCATION Throughout shop		

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION Extinguishers must be mounted and tagged throughout shop areas		
LOCATION 1420 Belfield Ave		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-136370

VIOLATIONS

PHILA. CODE § F-304.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Combustible waste material creating a fire hazard shall not be allowed to accumulate in buildings or structures or upon premises.		
CONDITION IN VIOLATION Remove any combustible waste materials.		
LOCATION 1420 Belfield Ave		

PHILA. CODE § F-5003.4.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Safety Data Sheets (SDS) shall be stored on the exterior of a facility (building wall, fence, post mounted, etc.) in a storage container at a location readily available to emergency responders on a 24-hour basis. The container shall be weather-resistant and locked by a padlock. Where there is a concern that the storage container may be subject to vandalism, installation of the container is permitted up to a maximum height of 10 feet (3048 mm). The location of the container shall be subject to approval by the fire department.		
CONDITION IN VIOLATION SDS sheets in a fire dept info box is required.		
LOCATION Front exterior wall		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-136370

VIOLATIONS

PHILA. CODE § F-5003.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Unless otherwise exempted by the fire code official, visible hazard identification signs as specified in NFPA 704 for the specific material contained shall be placed on stationary containers and aboveground tanks and at entrances to locations where hazardous materials are stored, dispensed, used or handled in quantities requiring a permit and at specific entrances and locations designated by the fire code official.		
CONDITION IN VIOLATION 704 diamond sign is required		
LOCATION Front exterior and paint mixing area		

PHILA. CODE § F-5003.5.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Individual containers, cartons or packages shall be conspicuously marked or labeled in an approved manner. Rooms or cabinets containing compressed gases shall be conspicuously labeled: COMPRESSED GAS.		
CONDITION IN VIOLATION Waste drums must be labeled		
LOCATION Waste storage drums.		

PHILA. CODE § F-2311.2.3.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Self-closing metal cans shall be used for oily waste.		
CONDITION IN VIOLATION A self closing can for oily rags is required.		
LOCATION Shop		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2025-136370



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 02/09/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: ERIC BROWN
Eric.Brown@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

توجہ فرمائیں: یہ ایک ضروری اطلاع نامہ ہے! ترجمے کی خدمات کے لیے 215-686-8686 پر کال کریں

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686