

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715



DISTRICT OFFICE

Fire Safety Unit
5th Fl
2401 Walnut St
Philadelphia, PA 19103
215-685-3917
FireSafetyUnit@phila.gov

PROPERTY IN VIOLATION

1800 ARCH ST, Philadelphia, PA 19103-2802

DATE OF NOTICE

02/14/2026

On 02/13/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 03/20/2026

VIOLATIONS

PHILA. CODE § F-901.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, mechanical smoke exhaust systems and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.		
CONDITION IN VIOLATION RESTORE FIRE ALARM PANEL TO DISPLAY NORMAL STATUS MAINTAIN IN OPERATIVE CONDITION AT ALL TIMES AND SHALL BE REPLACED OR REPAIRED WHERE DEFECTIVE.		
LOCATION 1800 ARCH ST (COMCAST TECHNOLOGY CENTER)		



✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715

VIOLATIONS

PHILA. CODE § F-701.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE The fire-resistance rating of the following fire-resistance-rated construction shall be maintained: 1. Structural members. 2. Exterior walls. 3. Fire walls, fire barriers, fire partitions. 4. Horizontal assemblies. 5. Shaft enclosures.		
CONDITION IN VIOLATION INSTALL MISSING FIRE RATED CEILING TILES		
LOCATION 59TH FL KITCHEN 48TH FL - LINEN STORAGE ROOM WHERE APPLICABLE		

PHILA. CODE § F-106.8	FINE AMOUNT \$1,000.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Obstruction of aisles, passageways or other means of egress constitutes a violation of this code. Upon finding any obstruction in an aisle, passageway or other means of egress, or upon finding any condition that constitutes a life safety hazard, the fire code official, in addition to any other remedy under this code, is authorized to cause any event or activity to be stopped until such condition or obstruction is corrected.		
CONDITION IN VIOLATION REMOVE OBSTRUCTIONS FROM AISLES, PASSAGEWAYS OR OTHER MEANS OF EGRESS.		
LOCATION 59TH FL DISWASHING ROOM 28TH FL NORTH SERVICE EGREES B3 CARPENTRY STORAGE ROOM 1 B3 L STORAGE- EXIT DOORS LAUNDRY PREPARATION KITCHEN- STORAGE WHERE APPLICABLE		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715

VIOLATIONS

PHILA. CODE § F-1013.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that any point in an exit access corridor or exit passageway is within 100 feet (30 480 mm) or the listed viewing distance of the sign, whichever is less, from the nearest visible exit sign.		
CONDITION IN VIOLATION INSTALL EXIT SIGNS		
LOCATION B3 L STORAGE		
PHILA. CODE § F-1104.28	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Exit doors in existing buildings shall be self-closing and latching and in accordance with Sections F-1104.28.1 and F-1104.28.2		
CONDITION IN VIOLATION MAINTAIN FIRE RATING DOORS MAKE SELF CLOSING AND LATCHING. REPLACE ANY MISSING HARDWARE.		
LOCATION 59TH FL SERVICE ELEVATOR LOBBY DOOR 57TH FL SERVICE ELEVATOR LINEN CLOSET DOOR 54TH FL SERVICE ELEVATOR-ELECTRICAL ROOM DOOR 52ND FL LINEN CLOSET DOOR WHERE APPLICABLE		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715

VIOLATIONS

PHILA. CODE § F-703.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer’s installation instructions.		
CONDITION IN VIOLATION FIRESTOP SYSTEMS SHALL BE SECURELY ATTACHED OR BONDED TO PROTECT MEMBRANE WALLS AND PENETRATIONS.		
LOCATION 59TH FL ELECTRICAL ROOM 58TH FL ELECTRICAL ROOM 57TH FL ELECTRICAL ROOM 52ND FL ELECTRICAL ROOM 47TH FL MECHANICAL ROOM B3 PARKING GARAGE WHERE APPLICABLE		

PHILA. CODE § F-604.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.		
CONDITION IN VIOLATION DISCONTINUE ALL IMPROPER USE OF MULTIPLUG ADAPTOR/EXTENSION CORD CONNECTIONS.		
LOCATION P-3 MECHANICAL ROOM- ELECTRICAL PANEL		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715

VIOLATIONS

PHILA. CODE § F-604.4.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Relocatable power taps shall be directly connected to a permanently installed receptacle.		
CONDITION IN VIOLATION DISCONTINUE IMPROPER USE OF EXTENSION CORDS SHALL NOT BE AFFIXED TO WALLS NOR RAN BETWEEN FLOORS		
LOCATION P-3 MECHANICAL ROOM- ELECTRICAL PANEL		

PHILA. CODE §	FINE AMOUNT	SCAN QR CODE FOR HOW TO RESOLVE
F-906.1	\$300.00	
PHILA. CODE LANGUAGE Portable fire extinguishers shall be installed in all of the following locations: 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. 2. Within 30 feet (9144 mm) distance of travel from commercial cooking equipment and from domestic cooking equipment in Group I-1; I-2, Condition 1; and R-2 college dormitory occupancies. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 3315.1. 5. Where required by the sections indicated in Table 906.1. 6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.		
CONDITION IN VIOLATION PROTABLE FIRE EXTINGUISHER SHALL BE INSTALLED, MOUNTED SERVICED AND TAGGED.		
LOCATION JG SKY HIGH- BAR AREA JG SKY HIGH- DINNING AREA		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715

VIOLATIONS

PHILA. CODE § F-906.7	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Hand-held portable fire extinguishers, not housed in cabinets, shall be installed on the hangers or brackets supplied. Hangers or brackets shall be securely anchored to the mounting surface in accordance with the manufacturer's installation instructions.		
CONDITION IN VIOLATION PROTABLE FIRE EXTINGUISHER SHALL BE INSTALLED, MOUNTED SERVICED AND TAGGED.		
LOCATION JG SKY HIGH-BAR AREA JG SKY HIGH- DINNING AREA		
PHILA. CODE § F-315.3.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Storage shall be maintained 2 feet (610 mm) or more below the ceiling in nonsprinklered areas of buildings or not less than 18 inches (457 mm) below sprinkler head deflectors in sprinklered areas of buildings.		
CONDITION IN VIOLATION REMOVE/ REDUCE TOP SHELF STORAGE, ALLOW 24 INCHES OF CLEARANCE FROM CEILING		
LOCATION 59TH FL-JG SKY HIGH- KITCHEN 48TH FL-FOUR SEASONS- LINEN CLOSET B-2- FOUR SEASONS- STORAGE ROOM VERNICK FISH- COOLER ALL STORAGE AREAS WHERE APPLICABLE		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715

VIOLATIONS

PHILA. CODE § F-604.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.		
CONDITION IN VIOLATION INSTALL APPROVED COVERS ON OPEN JUNCTION BOXES AND WIRING SPLICEING.		
LOCATION 59TH FL ELECTRICAL ROOM 58TH FL ELCETRICAL ROOM 51ST FL ELECTRICAL ROOM 46TH FL SUPPLY FAN VFD ROOM 46TH FL LANTERN LOUNGE AREA 32ND FL IDF ROOM 18TH FL ROOM C1810 P-3 SECURITY 1 ROOM WHERE APPLICABLE		

PHILA. CODE § F-5303.5.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity.		
CONDITION IN VIOLATION COMPRESSED CYLINDERS AND TANKS SHALL BE SECURED TO PREVENT FALLING.		
LOCATION LOADING DOCK- PIZZARIA SALVY-OFFICE		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715

VIOLATIONS

PHILA. CODE § F-5003.5	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Unless otherwise exempted by the fire code official, visible hazard identification signs as specified in NFPA 704 for the specific material contained shall be placed on stationary containers and aboveground tanks and at entrances to locations where hazardous materials are stored, dispensed, used or handled in quantities requiring a permit and at specific entrances and locations designated by the fire code official.		
CONDITION IN VIOLATION INSTALL HAZARD IDENTIFICATION SIGN NFPA 704		
LOCATION B3 L STORGAE FOUR SEASONS STORAGE- FLAMMABLE CLOSET		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-012715



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 03/16/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: ROBERTO RIVERA roberto.e.rivera@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

پر کال کریں 215-686-8686 **ترجمے کی خدمات کے لیے!** یہ ایک ضروری اطلاع نامہ ہے: **توجہ فرمائیے**

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686