

# ✕ Violation Notice and Order to Correct

**L&I File Number:** CF-2026-032836



**DISTRICT OFFICE**

Proactive Rental Inspections  
5th Fl  
2401 Walnut St  
Philadelphia, PA 19103  
215-685-1510  
ProactiveRentalInspections@phila.gov

**PROPERTY IN VIOLATION**

4927 N 12TH ST, Philadelphia, PA 19141-3509

**DATE OF NOTICE**

04/10/2026

On 04/09/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

## IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

**YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 05/14/2026**

### VIOLATIONS

|                                                                                                                                                                                                                                                                                                                                |                                            |                                                                                                                                             |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|
| <div>PHILA. CODE §</div> <div>9-3902 (2)</div>                                                                                                                                                                                                                                                                                 | <div>FINE AMOUNT</div> <div>\$300.00</div> | <div>SCAN QR CODE FOR HOW TO RESOLVE</div> <div></div> |
| <div>PHILA. CODE LANGUAGE</div> <div>The owner of any multiple family dwelling let for occupancy must obtain a rental license. No person shall collect rent with respect to any property that is required to be licensed pursuant to this Section unless a valid rental license has been issued for the property. 9-3902</div> |                                            |                                                                                                                                             |
| <div>CONDITION IN VIOLATION</div> <div>Obtain rental license</div>                                                                                                                                                                                                                                                             |                                            |                                                                                                                                             |
| <div>LOCATION</div> <div>4927 N 12th St</div>                                                                                                                                                                                                                                                                                  |                                            |                                                                                                                                             |

# ✕ Violation Notice and Order to Correct

**L&I File Number:** CF-2026-032836

## VIOLATIONS

|                                                                                                                                                                                                                                                                                                                                                                       |                                |                                                                                                                               |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|-------------------------------------------------------------------------------------------------------------------------------|
| <b>PHILA. CODE §</b><br>F-907.8.5                                                                                                                                                                                                                                                                                                                                     | <b>FINE AMOUNT</b><br>\$300.00 | <b>SCAN QR CODE FOR HOW TO RESOLVE</b><br> |
| <b>PHILA. CODE LANGUAGE</b><br><p>The building owner shall be responsible to maintain the fire and life safety systems in an operable condition at all times. Service personnel shall meet the qualification requirements of NFPA 72 for inspection, testing and maintenance of such systems. Records of inspection, testing and maintenance shall be maintained.</p> |                                |                                                                                                                               |
| <b>CONDITION IN VIOLATION</b><br><p>Have a licensed contractor test, and recertify fire alarm. Then upload it to the Phila eclipse system.</p>                                                                                                                                                                                                                        |                                |                                                                                                                               |
| <b>LOCATION</b><br><p>4927 N 12th St</p>                                                                                                                                                                                                                                                                                                                              |                                |                                                                                                                               |

  

|                                                                                                                                                                                                                                                                                                                                                                                    |                                |                                                                                                                                |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|--------------------------------------------------------------------------------------------------------------------------------|
| <b>PHILA. CODE §</b><br>PM15-604.3                                                                                                                                                                                                                                                                                                                                                 | <b>FINE AMOUNT</b><br>\$300.00 | <b>SCAN QR CODE FOR HOW TO RESOLVE</b><br> |
| <b>PHILA. CODE LANGUAGE</b><br><p>The electrical system at the premises constitutes a hazard to the occupants due to one or more of the following: inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the defects must be corrected to eliminate the hazard.</p> |                                |                                                                                                                                |
| <b>CONDITION IN VIOLATION</b><br><p>Have a licensed electrician place improperly ran wires in conduit for spot lights.</p>                                                                                                                                                                                                                                                         |                                |                                                                                                                                |
| <b>LOCATION</b><br><p>4927 N 12th St<br/>Rear</p>                                                                                                                                                                                                                                                                                                                                  |                                |                                                                                                                                |

  

|                                                                                                                                                                           |                                |                                                                                                                                 |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|---------------------------------------------------------------------------------------------------------------------------------|
| <b>PHILA. CODE §</b><br>PM15-308.1                                                                                                                                        | <b>FINE AMOUNT</b><br>\$300.00 | <b>SCAN QR CODE FOR HOW TO RESOLVE</b><br> |
| <b>PHILA. CODE LANGUAGE</b><br><p>All exterior property and premises, and the interior of every structure, shall be free from any accumulation of rubbish or garbage.</p> |                                |                                                                                                                                 |
| <b>CONDITION IN VIOLATION</b><br><p>Remove all rubbish, garbage and debris from property</p>                                                                              |                                |                                                                                                                                 |
| <b>LOCATION</b><br><p>4927 N 12th St<br/>side &amp; rear</p>                                                                                                              |                                |                                                                                                                                 |

# ✕ Violation Notice and Order to Correct

**L&I File Number:** CF-2026-032836

## VIOLATIONS

|                                                                                                                                                                                                                                                         |                                            |                                                                                                                                           |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------|
| <div>PHILA. CODE §</div> <div>F-1104.27</div>                                                                                                                                                                                                           | <div>FINE AMOUNT</div> <div>\$300.00</div> | <div>SCAN QR CODE FOR HOW TO RESOLVE</div> <div></div> |
| <div>PHILA. CODE LANGUAGE</div> <div>Stairways in the means of egress shall be free of obstructions. There shall be no storage under the stairways unless the area is enclosed with construction having at least a 1-hour fire-resistance rating.</div> |                                            |                                                                                                                                           |
| <div>CONDITION IN VIOLATION</div> <div>Remove boxes that are block an egress.</div>                                                                                                                                                                     |                                            |                                                                                                                                           |
| <div>LOCATION</div> <div>4927 N 12th St</div> <div>Rear stairs</div>                                                                                                                                                                                    |                                            |                                                                                                                                           |



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



**YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 05/10/2026.**

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at [www.phila.gov/li](http://www.phila.gov/li) or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

**IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.**

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.

# ✕ Violation Notice and Order to Correct

**L&I File Number:** CF-2026-032836



The Philadelphia Code may be found online for free at [www.phila.gov](http://www.phila.gov) under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: Mike Brown  
[Mike.A.Brown@phila.gov](mailto:Mike.A.Brown@phila.gov) or the district office noted above.

**ATTENTION:** This is an important notice! For information in your language, call 215-686-8686

**ATENCIÓN:** ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

**注意:** 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

**CHÚ Ý:** Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

**주의:** 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

**پر کال کریں** 215-686-8686 **ترجمے کی خدمات کے لیے!** یہ ایک ضروری اطلاع نامہ ہے: **توجہ فرمائیں**

**ATTENTION :** Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686

