

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-059654



DISTRICT OFFICE

Property Maintenance Unit
5th Fl
2401 Walnut St
Philadelphia, PA 19103
215-685-0535
PropertyMaintenanceUnit@phila.gov

PROPERTY IN VIOLATION

2600 W THOMPSON ST, Philadelphia, PA 19121-4699

DATE OF NOTICE

05/29/2026

On 05/28/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 07/02/2026

VIOLATIONS

PHILA. CODE § F-906.7	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Hand-held portable fire extinguishers, not housed in cabinets, shall be installed on the hangers or brackets supplied. Hangers or brackets shall be securely anchored to the mounting surface in accordance with the manufacturer's installation instructions.		
CONDITION IN VIOLATION INSTALL BRACKETS		
LOCATION COMPUTER ROOM LIBRARY		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-059654

VIOLATIONS

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION HAVE A LICENSE CONTRACTOR TAGG ALL FIRE EXTINGUISHERS		
LOCATION PROPERTY		

PHILA. CODE § F-1004.9	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space, for the intended configurations. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or the owner's authorized agent.		
CONDITION IN VIOLATION INSTALL OCCUPANCY SIGNS AS REQUIRED.		
LOCATION AUDITORIUM GYM/LUNCHROOM		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-059654

VIOLATIONS

PHILA. CODE § F-807.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE In Groups A, B, E, I, M and R-1 and in dormitories in Group R-2, curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall comply with Section 807.3 and shall not exceed 10 percent of the specific wall or ceiling area to which such materials are attached. Fixed or movable walls and partitions, paneling, wall pads and crash pads applied structurally or for decoration, acoustical correction, surface insulation or other purposes shall be considered to be interior finish, shall comply with Section 803 and shall not be considered decorative materials or furnishings.		
CONDITION IN VIOLATION FIRE-RATED CURTAINS. MUST BE TAGGED		
LOCATION AUDITORIUM STAGE		
PHILA. CODE § F-313.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Fueled equipment including, but not limited to, motorcycles, mopeds, lawn-care equipment, portable generators and portable cooking equipment, shall not be stored, operated or repaired within a building.		
CONDITION IN VIOLATION REMOVE ALL FUELED EQUIPMENT		
LOCATION BASEMENT HALLWAY		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-059654

VIOLATIONS

PHILA. CODE § F-304.2		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Storage of combustible rubbish shall not produce conditions that will create a nuisance or a hazard to the public health, safety or welfare.			
CONDITION IN VIOLATION MAINTAIN THE STORAGE ROOM IN A NEAT AND ORDERLY MANNER, ENSURING ALL ITEMS ARE PROPERLY STACKED AND EASILY ACCESSIBLE.			
LOCATION BASEMENT HALLWAY ART ROOM CLOSET ALL STORAGE CLOSET IN COMMON HALLWAYS STAGE CLOSET			

PHILA. CODE § F-5003.5		FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Unless otherwise exempted by the fire code official, visible hazard identification signs as specified in NFPA 704 for the specific material contained shall be placed on stationary containers and aboveground tanks and at entrances to locations where hazardous materials are stored, dispensed, used or handled in quantities requiring a permit and at specific entrances and locations designated by the fire code official.			
CONDITION IN VIOLATION INSTALL NFPA 704 SIGN AT BOTH ENTRANCES FOR GENERATOR ROOM			
LOCATION BASEMENT GENERATOR ROOM			

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-059654

VIOLATIONS

PHILA. CODE § F-1104.28	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Exit doors in existing buildings shall be self-closing and latching and in accordance with Sections F-1104.28.1 and F-1104.28.2		
CONDITION IN VIOLATION FIRE DOOR SHOULD LACK PROPERLY		
LOCATION MAIN ENTRANCE DOORS AUDITORIUM DOOR IN HALLWAY		

PHILA. CODE § F-906.2	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.		
CONDITION IN VIOLATION INSTALL K FIRE EXTINGUISHER		
LOCATION KITCHEN / WARMING AREA		



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-059654



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 06/28/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: Kevin Wooten Kevin.Wooten@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

پر کال کریں 215-686-8686 **ترجمے کی خدمات کے لیے!** یہ ایک ضروری اطلاع نامہ ہے: **توجہ فرمائیے**

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686