

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-060753



DISTRICT OFFICE

Property Maintenance Unit
9359 Krewstown Rd
Philadelphia, PA 19115
215-685-0535
PropertyMaintenanceUnit@phila.gov

PROPERTY IN VIOLATION

6610 TORRESDALE AVE, Philadelphia, PA 19135-2828

DATE OF NOTICE

06/04/2026

On 06/03/2026 the Department of Licenses and Inspections inspected/investigated the property in violation and found the following condition(s) or activity which violate the Philadelphia Code. Based on these the property is deemed:

IN VIOLATION

The property will remain in this status until all the violations below are corrected and the Department of Licenses and Inspections has verified the corrective action. You are the person responsible for the correction of these violations.

Any permit or license obtained to comply a violation of working without or in excess of a permit or a license will result in an additional inspection fee equal to the cost of the permit or license. (Phila. Code § A-901.13)

YOU ARE ORDERED TO MAKE THE NECESSARY REPAIRS AND/OR TAKE THE NECESSARY ACTION(S) TO CORRECT THE CITED CONDITIONS PRIOR TO 07/08/2026

VIOLATIONS

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-060753

VIOLATIONS

PHILA. CODE § PM15-305.3	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking or abraded paint shall be repaired, removed or covered. Cracked or loose plaster, decayed wood and other defective surface conditions shall be corrected.		
CONDITION IN VIOLATION The ceiling of the stairs at the entrance had unsealed gaps around the edges of the drywall. The stairs had damaged walls in the stairs and exposed wire on one side. The kitchen wall is damaged next to a light switch. The kitchen walls had a crack. The wooden flooring is bulging up in the hallway. The ceiling is peeling off in the middle room. The hallways had damaged flooring which is rising and causing a tripping hazard. Please fix and seal all the damaged, cracked, water-stained and holes in the walls, ceilings and flooring in the above-named locations.		
LOCATION Second floor unit at 6610 Torresdale avenue.		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-060753

VIOLATIONS

PHILA. CODE § F-604.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible code official. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.		
CONDITION IN VIOLATION The rear children's bedroom has an electrical panel that is missing the face covers and has exposed wires. The panel is behind an unlocked decorative enclosure. There was an outlet multiplier and a extension cord in use in the kitchen. Please install a cover plate on the electrical panel and remove the extension cord and outlet multipliers in the kitchen.		
LOCATION second floor unit at 6610 Torresdale avenue.		

PHILA. CODE § F-1103.8	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Single- and multiple-station (single-station wired together to enable all to sound an alarm when one activates) smoke alarms shall be installed in existing Group R occupancies in accordance with Sections F-1103.8.1 through F-1103.8.3.		
CONDITION IN VIOLATION The smoke alarm in the front stairs failed to function when tested. There is a missing smoke alarm in the hallway near the bathroom. Please install smoke alarms or combo smoke /Co alarms in the above-named locations.		
LOCATION Second floor unit of the property at 6610 Torresdale avenue.		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-060753

VIOLATIONS

PHILA. CODE § PM15-305.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE (QR Code Unavailable)
PHILA. CODE LANGUAGE Every interior door shall fit reasonably well within its frame and shall be capable of being opened and closed by being properly and securely attached to jambs, headers, or tracks.		
CONDITION IN VIOLATION The front bedroom is missing the door. The rear children's bedroom is missing the door. Please install doors in the front and rear bedrooms.		
LOCATION Front and rear bedrooms of the second floor unit at 6610 Torresdale avenue.		

PHILA. CODE § PM15-504.1	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks and defects and be capable of performing the function for which such plumbing fixtures are designed. All plumbing fixtures shall be maintained in a safe, sanitary and functional condition.		
CONDITION IN VIOLATION The kitchen sink has a leaking faucet and there is no hot water. There is water damaged wood inside the pipe chase from a leak. The bathtub faucet is leaking. The bathroom sink that had air rumbling in piping when turned on. Please have licensed plumber fix all the leaking fixtures, purge the piping of the air, and restore hot water to the unit. Provide written documentation work done.		
LOCATION Second floor unit of the property at 6610 Torresdale avenue.		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-060753

VIOLATIONS

PHILA. CODE § F-1103.9	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE Carbon monoxide alarms shall be installed in existing dwelling units or sleeping units in accordance with Sections F-1103.9.1 through F-1103.9.3 where any of the conditions in Sections 915.1.2 through 915.1.6 exist. A carbon monoxide detection system installed in accordance with Section 915.5 shall be an acceptable alternative to carbon monoxide alarms.		
CONDITION IN VIOLATION I did not see any carbon Monoxide alarms in the unit. Please install a Carbon monoxide alarm or a combo smoke/Co alarm in the second-floor unit.		
LOCATION Second floor unit at the property at 6610 Torresdale avenue.		

PHILA. CODE § PM15-304.6	FINE AMOUNT \$300.00	SCAN QR CODE FOR HOW TO RESOLVE 
PHILA. CODE LANGUAGE All exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent deterioration.		
CONDITION IN VIOLATION There was loose brickwork at the corner of the front wall. There were an unsealed crack and gap in the side wall brickwork. The interior front entrance had exposed brickwork at the top of the front door wall. Please fix the damaged exterior walls and cover the exposed brickwork inside the entrance vestibule.		
LOCATION Property at 6610 Torresdale street.		

✕ Violation Notice and Order to Correct

L&I File Number: CF-2026-060753



Failure to timely correct the violations listed above by or before the correction date listed above will result in the stated fine amount being imposed against you. The fines will be imposed on a per day basis for each violation that remains uncorrected AFTER the stated correction date. Phila. Code § A-601. If you timely correct each violation by the stated correction date, no fines will be due.

In addition to the fines listed above, failure to timely correct the violations will result in you being charged:

- Labor and material costs for any work performed by the City, such as a demolition; sealing of windows or doors; clearing of weeds, trash or debris; relocation expenses for removing occupants, costs associated with cease operations orders. Such costs are subject to an additional administrative fee of 21% (Phila. Code § A-503);
- An additional \$100 fee for repeat abatement work (Phila. Code § A-503.2); and
- Reinspection fees as follows: \$100 for the third inspection, \$200 for the fourth inspection, and \$350 for any additional inspections (Phila. Code § A-901.12.2).



YOU HAVE THE RIGHT TO APPEAL THIS NOTICE. YOUR APPEAL MUST BE FILED BY 07/04/2026.

IF YOU DO NOT TIMELY FILE AN APPEAL THEN YOU WAIVE YOUR RIGHT TO LATER CHALLENGE ANY PART OF THIS NOTICE. This includes waiving your right to argue: whether the violations existed, whether you were responsible to correct the violations, whether you had enough time to correct the violations, whether the City should have abated the violations, and whether the City can impose fines, fees, or costs against you.

For more information on filing an appeal and/or to obtain the approved form visit the appeals section of the Department of Licenses and Inspections website at www.phila.gov/li or the Boards Administration Unit, Concourse Municipal Services Building, 1401 J.F.K. Blvd., Philadelphia PA.

Appeals of the Technical Codes, such as the Zoning Code and/or Fire Code, need to be submitted to the appropriate Technical Appeal Board such as the Zoning Board of Adjustment and/or the Board of Safety and Fire Prevention. For additional information call 215-686-8686.

IF YOU HAVE ANY LEGAL QUESTIONS YOU SHOULD CONSULT WITH AN ATTORNEY.

If you do not have an attorney, you can contact the Philadelphia Bar Association Referral and Information Line at 215-238-6333 to have an attorney referred to you. You can also find a list of legal aid service providers at <http://palegalaid.net/legal-aid-providers-in-pa>.



The Philadelphia Code may be found online for free at www.phila.gov under "Open government."

If you have any questions regarding this notice or would like to schedule a re-inspection, please contact: Fernando Diotti Fernando.Diotti@phila.gov or the district office noted above.

ATTENTION: This is an important notice! For information in your language, call 215-686-8686

ATENCIÓN: ¡Este es un aviso Importante! Para recibir información en su idioma, llame al 215-686-8686

注意: 这是重要通知! 如果您需要以您的语言获得此信息, 请致电 215-686-8686

CHÚ Ý: Đây là thông báo quan trọng! Nếu bạn cần thư này bằng ngôn ngữ khác, vui lòng gọi 215-686-8686

주의: 중요 통지입니다! 이 서신을 귀하의 언어로 받고 싶으시면 215-686-8686번으로 전화하시기 바랍니다

پر کال کریں 215-686-8686 **ترجمے کی خدمات کے لیے!** یہ ایک ضروری اطلاع نامہ ہے: **توجہ فرمائیے**

ATTENTION: Cet avis est important ! Si vous avez besoin de cet avis dans une autre langue, appelez le 215-686-8686